Wastewater Management Section

List of Registered On-site Treatment and Distribution Products

As Established in Chapter 246-272A WAC

April 2024



For information or additional copies of this report contact:

Wastewater Management Program

Physical address: 101 Israel Road SE, Tumwater, WA 98501

Mailing Address: PO Box 47824, Olympia, Washington 98504-7824

Phone: 360-236-3330 FAX: 360-236-2257

Webpage: www.doh.wa.gov/wastewater

Email: wastewatermanagement@doh.wa.gov

Umair A. Shah, MD, MPH Secretary of Health

To request this document in another format, call 1-800-525-0127. Deaf or hard of hearing customers, please call 711 (Washington Relay) or email civil.rights@doh.wa.gov.

Para solicitar este documento en otro formato, llame al 1-800-525-0127. Clientes sordos o con problemas de audición, favor de llamar al 711 (servicio de relé de Washington) o enviar un correo electrónico a civil.rights@doh.wa.gov.

DOH 337-024

Contents

| SECTION 1 – Introduction and Overview | 3 |
|--|----|
| Categories of Treatment Product and Treatment Levels | |
| SECTION 2 – List of Manufacturers of Registered Proprietary On-site Products | 9 |
| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | 10 |
| Manufacturers of Registered Category 2 Proprietary On-site Treatment Products | |
| Manufacturers of Registered Category 3 Proprietary On-site <i>Treatment</i> Products | |
| Manufacturers of Registered Proprietary On-site Distribution Products | 37 |
| SECTION 3 – List of Registered On-site Treatment and Distribution Products | 41 |
| Registered On-site <i>Treatment</i> Products | 42 |
| Registered On-site <i>Distribution</i> Products | 40 |

Glossary of Termshttp://www.doh.wa.gov/Portals/1/Documents/Pubs/337-028.pdf

NOTE:

The presence of a product on this list does not constitute approval of marketing, advertising, or labeling practices employed by a manufacturer, nor is it an affirmation of manufacturer claims of product performance. Registration listing does not constitute endorsement of these products by the Washington State Department of Health. Information obtained from the sources listed is the sole responsibility of the manufacturer or other provider.

Links to external resources are provided as a public service, and do not imply endorsement by the Washington State Department of Health.

DOH 337-024 Page 2 of 53

SECTION 1 – Introduction and Overview

Chapter 246-272A WAC establishes a process for proprietary on-site product registration with requirements for testing, testing protocols, performance thresholds levels, and application processes. This registration process replaces the previous requirement of having to be on the "List of Approved Systems and Products" (Approved List). When the Washington State Department of Health (DOH or "the department") has determined that a product meets the registration requirements that are established in the rules, the product will be placed on the "List of Registered On-site Treatment and Distribution Products" (Registered List). This document is a revision to the initial edition of the "Registered List".

Beginning March 16, 2007, product registration became a condition of approval for use of all proprietary treatment and distribution products, and local health jurisdictions may only permit products that are on the "Registered List".

All types of sewage technologies must either have standards for use described in WAC 246-272A or departmental Recommended Standards and Guidance (RS&G) before the local health officer may permit them. Specific conditions for the use of each system technology or product are described in the RS&G documents relevant to the proprietary device. The most recently published edition of any RS&G can be obtained from our website on: http://www.doh.wa.gov/ CommunityandEnvironment/WastewaterManagement/FormsPublications.aspx.

Product models, rated capacities, treatment processes, treatment levels, and dimensional descriptions information are included in the tables of this document. In addition, terms used in this document, which need definition or clarification, are provided in Section 4 - Glossary of terms. This information is provided to facilitate equipment selection and promote proper application of the technology.

We welcome suggestions to improve this document. If you identify an error or have an idea about how to improve the usefulness of this document, feel free to contact staff in the Wastewater Management Program at the Washington State Department of Health, Office of Environmental Health and Safety at 360-236-3330.

DOH 337-024 Page 3 of 53

Overview

Treatment components or distribution technologies, both proprietary and public domain (other than a sewage tank, or a gravel-filled drainfield fed either by a gravity or pressure distribution network), must be on the Department's "Registered List" before they may be permitted by the local health officer. Prior to placement on this list, the following must occur:

- 1. For all treatment components and distribution technologies other than sewage tanks, the Department of Health, with the assistance of the Technical Advisory Group (TAG), may develop guidance in the form of Recommended Standards and Guidance (RS&G) for a particular type of technology. Each RS&G may include application, design, installation, operation, monitoring and maintenance, and performance expectation information.
- 2. For proprietary treatment and distribution products, the manufacturer has submitted an application for registration containing the information required by WAC 246-272A. For proprietary treatment products, this information shall verify that the performance of the proprietary treatment product was tested according to the appropriate testing protocol and include the results of the testing.
- 3. The department will verify the information on the application and register the product if all the required information and data are included in the application.

Categories of Treatment Product and Treatment Levels

This document registers the category and treatment level that is met by a treatment product. Applicable terms to help understand this listing include:

Category 1 treatment product – a treatment component designed to treat sewage typical of a residential source when septic tank effluent is anticipated to be equal to or less than Treatment Level E (*See Table 1*).

Category 2 treatment product – a treatment component designed to treat high-strength sewage when septic tank effluent is anticipated to be greater than Treatment Level E. Examples of sources of high-strength sewage usually include restaurants, grocery stores, mini-marts, group homes, medical clinics, or residences.

DOH 337-024 Page 4 of 53

Category 3 treatment product – a black water (human wastes) component of residential sewage. The primary examples are composting and incinerating toilets.

Treatment Level – one of 5 levels (A, B, C, E, & N), and one of 3 bacterial levels (BL1, BL2, or BL3) as noted in Table 1 and used in WAC 246-272A to:

- (a) Identify treatment component performance demonstrated requirements specified in WAC 246-272A-0110, and
- (b) Match site conditions of vertical separation and soil type with treatment components. Treatment levels used in WAC 246-272A are not intended to be applied as field compliance standards. Their intended use is for establishing treatment product performance in a product testing setting under established protocols by qualified testing entities.

Table 1. Treatment Levels

| Level | Parameters | | | | | |
|-------|-----------------|---------------|---------------|------------------|--------------|-----------------------|
| | CBOD₅ (mg/L) | TSS (mg/L) | O&G (mg/L) | FC (#/100 ml) | TN (mg/L) | E. coli cfu/100 mL |
| Α | 10 | 10 | | | | |
| В | 15 | 15 | | | | |
| С | 25 | 30 | | | | |
| BL1 | | | | 200 | | 126 |
| BL2 | | | | 1,000 | | |
| BL3 | | | | 50,000 | | |
| E | 228 | 80 | 20 | | | |
| N | | | | | 30 | |

Note:

DOH 337-024 Page 5 of 53

Values for Levels A - C are maximum 30-day values (averages for CBOD₅, TSS, and geometric mean for FC.) All 30-day averages throughout the test period must meet these values in order to be registered at these levels. Values for Levels E and N are derived from full test averages.

DOH 337-024 Page 6 of 53

Changes from previous versions

The following table shows a list of the changes from previous versions:

| Product changes to the Approved List | | | |
|--------------------------------------|------------------------------------|-------------------------|-------------------------|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Level |
| | Singulair Wastewater Treatment | | |
| Norweco, Inc. | System (TNT series) | | |
| 220 Republic Street | Singulair TNT-500 | 500 | |
| Norwalk, OH 44857-1196 | Singulair TNT-500 | 600 | Added Treatment Level N |
| | Singulair TNT-750 | 750 | |
| Tel: 419-668-4471 | Singulair TNT-750 | 800 | |
| Fax: 419-663-5440 | Singulair TNT-1000 | 1000 | |
| E-mail: | Singulair TNT-1250 | 1250 | |
| customerservice@norweco.com | Singulair TNT-1500 | 1500 | |
| Web: <u>www.norweco.com</u> | Singulair TNT-OP-500 | 500 | |
| | Singulair TNT-OP-500 | 600 | |
| | Singulair TNT-OP-1000 | 1000 | |
| | Singulair Wastewater Treatment | | |
| | System TNT series with the Norweco | | |
| | AT1500 UV Unit | | |
| | | | Added Treatment Level N |
| | Singulair TNT-500 – 1 UV Unit | 500 | |
| | Singulair TNT-500 – 2 UV Units | 600 | |
| | Singulair TNT-750 – 2 UV Units | 750 | |
| | Singulair TNT-750 – 2 UV Units | 800 | |

DOH 337-024 Page 7 of 53

| Singulair TNT-1000 – 2 UV Units | 1000 | |
|------------------------------------|------|--|
| Singulair TNT-1250 – 3 UV Units | 1250 | |
| Singulair TNT-1500 – 3 UV Units | 1500 | |
| Singulair TNT-OP-500 – 1 UV Unit | 500 | |
| Singulair TNT-OP-500 – 2 UV Units | 600 | |
| Singulair TNT-OP-1000 – 2 UV Units | 1000 | |
| | | |

DOH 337-024 Page 8 of 53

SECTION 2 – List of Manufacturers of Registered Proprietary On-site Products

This section presents the current list of manufacturers who have submitted proprietary treatment and/or proprietary distribution products for DOH review and were found to meet the registration requirements in WAC 246-272A. This list notes the manufacturer, the manufacturer's contact information, products' names/models that have been reviewed and registered by DOH, and product treatment processes or type. To determine what the specific products are registered for, see Section 3.

If a certain manufacturer or product is not listed, or if a listed manufacturer's specific model number is not included on the list, the product IS NOT APPROVED for use in Washington State and may not be permitted by the local health officer.

Disclaimer

The manufacturers' contact information is presented here for information purposes only. Product registration and listing does not constitute departmental approval of marketing, advertising or labeling practices employed by a manufacturer, nor does it constitute an endorsement of these products, nor a preference among the manufacturers.

DOH 337-024 Page 9 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | | |
|---|--|-------------------------|------------------------|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
| Anua PO Box 77457 | Puraflo Peat Fiber Biofilter Wastewater Treatment System | | | |
| Greensboro, NC 27417 | , | | | |
| | P150N 3A | 450 | | |
| Tel: 800-787-2356 | P150N 3B | 450 | | |
| Tel: 336-547-9338 | P150N 4A | 600 | | |
| Fax: 336-547-8559 | P150N 4B | 600 | | |
| Web: <u>www.anuainternational.com</u> | P150N 5A | 750 | Attached Growth | |
| | P150N 5B | 750 | Single-pass Packed Bed | |
| | P150N 6A | 900 | Filter | |
| | P150N 6B | 900 | | |
| | P150N 7B | 1050 | | |
| | P150N 8B | 1200 | | |
| | P150N 9B | 1350 | | |
| | P150N 10B | 1500 | | |
| | Type "A" models have weep holes. Type "B" models are closed bottomed. | | | |

DOH 337-024 Page 10 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | | |
|---|--|-------------------------|----------------------|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
| Bio-Microbics, Inc. | FAST Wastewater Treatment System* | | | |
| 16002 West 110 th Street | RetroFAST 0.375 | 375 | Attached & Suspended | |
| Lenexa, KS 66219 | MicroFAST 0.5 | 500 | Growth | |
| | MicroFAST 0.625** | 625 | | |
| Tel: 800-753-3278 | MicroFAST 0.75 | 750 | | |
| Tel: 913-422-0707 | MicroFAST 0.9 | 900 | | |
| Fax: 913-422-0808 | MicroFAST 1.5 | 1500 | | |
| E-mail: onsite@biomicrobics.com | MicroFAST 3.0** | 3000 | | |
| Web: <u>www.biomicrobics.com</u> | MicroFAST 4.5** | 4500 | | |
| | MicroFAST 9.0** | 9000 | | |
| | *These models are also listed in Category 2. | | | |
| | **For Total Nitrogen reduction supplemental | | | |
| | BOD may be applied in the form of MicroC™ | | | |
| | when the influent BOD:TKN ratio is less than | | | |
| | 4:1. For Total Nitrogen applications with or | | | |
| | without the addition of MicroC™ the system | | | |
| | design will require a review by Bio-Microbics, | | | |
| | Inc. | | | |

DOH 337-024 Page 11 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | | |
|---|--|--|---|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
| Bio-Microbics, Inc. (continued) | FAST, Wastewater Treatment System with the Salcor 3G UV disinfection unit* MicroFAST 0.5 with the Salcor 3G MicroFAST 0.625 with the Salcor 3G – 2** MicroFAST 0.75 with the Salcor 3G – 2** MicroFAST 0.9 with the Salcor 3G – 2** MicroFAST 1.5 with the Salcor 3G – 3** MicroFAST 3.0 with the Salcor 3G – 6** MicroFAST 4.5 with the Salcor 3G – 7** MicroFAST 9.0 with the Salcor 3G – 7** *MicroFAST treated effluents are split to multiple Salcor 3G units proportionally so that each UV unit receives no more than 500 gpd. | 500 625 750 900 1500 3000 4500 9000 | Attached & Suspended Growth & UV Disinfection Treatment Sequence | |
| | **For Total Nitrogen reduction supplemental BOD may be applied in the form of MicroC™ when the influent BOD:TKN ratio is less than 4:1. In model applications with or without the addition of MicroC™ the system design will require a review by Bio-Microbics, Inc. BioBarrier MBR, Wastewater Treatment System | | | |
| | MBR 0.5 MBR 1.0 MBR 1.5 | 500 1000 1500 | Membrane Bioreactor | |

DOH 337-024 Page 12 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | | |
|---|---|-------------------------|-----------------------|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
| Bio-Microbics, Inc. | | | | |
| (continued) | BioBarrier MBR, Wastewater Treatment System | | | |
| | MBR 0.5-N | 500 | | |
| | MBR 1.0-N | 1000 | Membrane Bioreactor | |
| | MBR 1.5-N | 1500 | with Nitrogen | |
| | Requires a three-compartment tank w/ a mixing | | Reduction | |
| | pump in the middle chamber. | | | |
| | pamp in the madic chamber. | | | |
| Busse Green Technologies, Inc | Busse Wastewater Treatment System | | | |
| 1101 S Euclid Avenue | | 400 | | |
| Oak Park, IL 60304 | GT-400 | 600 | Membrane Bioreactor | |
| , | GT-600 | 800 | | |
| Tel: 708-204-3504 | GT-800 | 1000 | | |
| E-mail: info@busse-gt.com | GT-1000 | 1200 | | |
| Web: www.busse-gt.com | GT-1200 | | | |
| www.bussegt.com | | | | |
| | *Protection from freezing is required | | | |
| | | | | |
| Clearstream Wastewater Systems, Inc. | Clearstream Aerobic Treatment Units | | Extended aeration | |
| PO Box 7568 | 500D/DC, 500DS/DSC, 500DST, 500DT, | 500 | mode of the Activated | |
| Beaumont, TX 77712-1500 | 500DC2, 500DC2P, 500DC3-500, 500DC3-7500 | 500 | Sludge process | |
| | 600D/DC, 600DT, 600DC2, 600DC3 | 600 | | |
| Tel: 409-755-1500 | 1000DD, 1000DCD, 1000DTD | 1000 | | |
| Email: governmentaffairs@clearstreamsystems.com | | | | |

DOH 337-024 Page 13 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | | |
|---|---|---------------------------------|---|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
| Web: www.clearstreamsystems.com Clearstream Wastewater Systems, Inc. (continued) | Clearstream 500G Series Aerobic Treatment Units with CS 120 UV disinfection unit 500G/GC, 500GS/GSC., 500GST, 500GT, 500GC2, 500GC2P, 500GC3-500, 500GC3-750 Clearstream Aerobic Treatment Units 500G/GC, 500GS/GSC, 500GST, 500GT, 500GC2, 500GC2P, 500GC3-500, 500GC3-750 600G/GC, 600GT, 600GC2, 600GC3 | 500 500 500 500 600 | Extended aeration mode of the Activated Sludge process and UV Disinfection Treatment Sequence Extended aeration mode of the Activated Sludge process | |
| | 1000GD, 1000GCD, 1000GTD Clearstream Aerobic Treatment Units 500DA/DAC, 500DAS/DASC, 500DAST, 500DAT, 500DAC2, 500DAC3-500, 500DAC3-750, 500DAU 600DA/DAC, 600DAT, 600DAC2, 600DAC3, 600DAU 800DA/DAC, 800DAT, 800DAC2 | 1000 500 600 800 | Extended aeration mode of the Activated Sludge process | |

DOH 337-024 Page 14 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
|--|---|-------------------------|---|
| Consolidated Treatment System, Inc. 1501 Commerce Center Drive Franklin, OH 45005 Tel: 937-746-2727 | Enviro-Guard Wastewater Treatment System ENV-0.75 with the Salcor 3G UV disinfection unit | 750 | Suspended Growth with Filtration Process & UV Disinfection Treatment Sequence |
| Fax: 937-746-1446 | | | |
| E-mail: jeff@consolidatedtreatment.com | Multi-Flo Wastewater Treatment System | 500 | |
| Web: <u>www.consolidatedtreatment.com</u> | FTB-0.5 | 500 | Suspended Growth |
| | FTB-0.6 FTB-0.75 | 600 750 | with Filtration Process |
| | FTB-0.75 | 1000 | |
| | FTB-1.5 | 1500 | |
| | Nayadic Wastewater Treatment System | | |
| | M-6A-F/M-6 | 500 | Suspended Growth |
| | M-6A-C/M-6AC-F | 500 | |
| | M-8A-F/M-8A | 600 | |
| | M-1050-F/M-1050A | 800 | |
| | M-1200-F/M-1200A | 1000 | |
| | M-2000-F/M-2000A | 1500 | |

DOH 337-024 Page 15 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
|---|--|-------------------------|--------------------|
| Delta Treatment Systems, LLC | Whitewater DF Series Aerobic Treatment Units | | |
| A wholly owned subsidiary of Infiltrator | DF75 | 750 | |
| Water Technologies, LLC | DF100 | 1000 | Suspended Growth |
| | DF100A | 1000 | |
| 4 Business Park Road / PO Box 768 Old Saybrook, CT 06475 | DF150 | 1500 | |
| Tel: 800-221-4436 | Whitewater DF Series Aerobic Treatment Units | | Suspended Growth & |
| ax: 800-577-7000 | with the Salcor 3G UV disinfection unit | | UV Disinfection |
| -mail: info@infiltratorwater.com | DF50 with Salcor 3G | 500 | Treatment Sequence |
| Web: <u>www.deltatreatment.com</u> | DF60 with Salcor 3G | 600 | |
| | Whitewater DF Series Aerobic Treatment Units | | Suspended Growth & |
| | with Jet Illumi-Jet UV | | UV Disinfection |
| | DF50 with Jet Illumi-Jet UV | 500 | Treatment Sequence |
| | DF60 with Jet Illumi-Jet UV | 600 | |
| | Whitewater DF Series Aerobic Treatment Units | | Suspended Growth & |
| | with Norweco AT 1500 UV | | UV Disinfection |
| | DF50 with Norweco AT 1500 UV | 500 | Treatment Sequence |
| | DF60 with Norweco AT 1500 UV | 600 | |

DOH 337-024 Page 16 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | | |
|---|---|-------------------------|--|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
| Delta Treatment Systems (continued) | ECOPOD Fixed Film Wastewater Treatment System E50 E60 | 500 600 | Attached Growth | |
| | ECOPOD Fixed Film Wastewater Treatment System with the Salcor 3G UV disinfection unit E50 with Salcor 3G E60 with Salcor 3G | 500 600 | Attached Growth & UV Disinfection Treatment Sequence | |

DOH 337-024 Page 17 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | |
|---|--------------------------------------|-------------------------|-------------------|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
| | ECOPOD N Series Wastewater Treatment | | |
| | System | | |
| Delta Treatment Systems | E50NCA | 500 | |
| (continued) | E50-N-IM1060 | 500 | |
| | E50-N-CM1060 | 500 | Attached Growth |
| | E60NCA | 600 | |
| | E60-N-IM1060 | 600 | |
| | E60-N-CM1060 | 600 | |
| | E75NCA | 750 | |
| | E75-N-IM1060 | 750 | |
| | E75-N-CM1060 | 750 | |
| | E100NCA | 1000 | |
| | E150NCA | 1500 | |
| | E200-NFF | 2000 | |
| | E250-NFF | 2500 | |
| | E300-NFF | 3000 | |
| | | | |

DOH 337-024 Page 18 of 53

| ECOPOD N Series Wastewater Treatment System with the Salcor 3G UV disinfection unit E50NCA E50-N-IM1060 | Rated Capacity (gpd) | Treatment Process |
|---|---|---|
| System with the Salcor 3G UV disinfection unit E50NCA | 500 | |
| E50NCA | 500 | |
| | 500 | |
| F50-N-IM1060 | | |
| 200 11 11112000 | 500 | |
| E50-N-CM1060 | 500 | |
| E60NCA | 600 | Attached Growth an |
| E60-N-IM1060 | 600 | UV Disinfection |
| E60-N-CM1060 | 600 | Treatment Sequence |
| E75NCA | 750 | |
| E75-N-IM1060 | 750 | |
| E75-N-CM1060 | 750 | |
| E100NCA | 1000 | |
| E150NCA | 1500 | |
| E200-NFF | 2000 | |
| E250-NFF | 2500 | |
| E300-NFF | 3000 | |
| | E60-N-IM1060 E60-N-CM1060 E75NCA E75-N-IM1060 E75-N-CM1060 E100NCA E150NCA E200-NFF | E60-N-IM1060600E60-N-CM1060600E75NCA750E75-N-IM1060750E75-N-CM1060750E100NCA1000E150NCA1500E200-NFF2000E250-NFF2500 |

DOH 337-024 Page 19 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | |
|---|--|-------------------------|---|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
| Ecological Tanks, Inc | Aqua Safe Series | | |
| 2247 Highway 151 North | AS500 | 500 | |
| Downsville, LA 71234 | AS600 | 600 | |
| | AS750 | 750 | |
| Tel: 800-277-8179 | AS1000 | 1000 | Suspended Growth |
| Tel: 318-644-0397 | AS1500 | 1500 | |
| Fax: 618-644-7257 | | | |
| E-mail: aquasafe@bayou.com | AS500L | 500 | |
| Web: www.etiaquasafe.com | AS600L | 600 | |
| | AS800L | 800 | |
| | AS1100L | 1100 | |
| | Aqua Safe AS600 + 4NR | 600 | Suspended Growth |
| | Aqua Safe AS600 + 4NR w/ Disinfector UV and Salcor 3G UV | 600 | Suspended Growth & UV Disinfection Treatment Sequence |

DOH 337-024 Page 20 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
|----------------------------------|----------------------------|-------------------------|----------------------|
| Ecological Tanks, Inc | | | |
| (continued) | Aqua Aire Series | | |
| | AA500 | 500 | |
| | AA600 | 600 | |
| | AA750 | 750 | Suspended Growth |
| | AA800 | 800 | |
| | AA1000 | 1000 | |
| | AA1200 | 1200 | |
| | AA1500 | 1500 | |
| Eljen Corporation | GSF A42 | 450 | Single pass Attached |
| 90 Meadow Rd | | 600 | Growth Geotextile |
| Windsor, CT 06095 | | 750 | Sand Filter |
| , | | 900 | |
| Tel: 800-444-1359 | | 1050 | |
| Fax: 860-610-0427 | | 1200 | |
| E-mail: <u>jking@eljen.com</u> | | 1350 | |
| Web: www.eljen.com | | 1200 | |
| | | 1350 | |
| | | 1500 | |
| Enviro-Flo, Inc. | NuWater | | Suspended Growth 8 |
| 151 Custom Drive | Model B-500 with Salcor 3G | 500 | UV Disinfection |
| Flowood, MS 39232 | | | Treatment Sequence |

DOH 337-024 Page 21 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | |
|---|---|---|--|
| Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
| | | | |
| - | | | |
| | | Suspended Growth | |
| | | | |
| | | | |
| | | | |
| E-1000 | 1000 | | |
| NuWater | | | |
| BNR 500 | 500 | Suspended Growth | |
| BNR 600 | 600 | | |
| BNR750 | 750 | | |
| BNR850 | 850 | | |
| BNR1000 | 1000 | | |
| BNR1500 | 1500 | | |
| NuWater | | Suspended Growth & | |
| | 500 | UV | |
| BNR 600 with Salcor 3G UV | 600 | Disinfection Treatment Sequence | |
| | Product Name/Model Enviro-Flo Wastewater Treatment System E-500 E-550 E-600 E-750 E-1000 NuWater BNR 500 BNR 600 BNR750 BNR850 BNR1000 BNR1500 NuWater BNR 500 With Salcor 3G UV | Product Name/Model Rated Capacity (gpd) | |

DOH 337-024 Page 22 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | |
|--|---|--|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
| Fuji Clean, USA, LLC 41-2 Greenwood Road Brunswick, ME 04011 Tel: 207-406-2927 Fax: 207-406-2929 E-mail: info@fujicleanusa.com Web: www.fujicleanusa.com | CEN5 with Salcor 3G UV CEN7 with Salcor 3G UV CEN10 with Salcor 3G UV | 450 630 900 | Attached & Suspended Growth with UV Disinfection Treatment Sequence |
| Glendon BioFilter Technologies, Inc. PO Box 2585 Gig Harbor, WA 98335 Tel: 206-819-8803 E-mail: paulv@glendon.com Web: www.glendon.com | Glendon BioFilter Treatment System M31* *Multiple units, in the same or a variety of sizes, may be used in parallel to accomplish daily design flows to 3,500 gpd. | 120 (per each prefabricate d basin) | Upflow Media Filtration |
| | Glendon BioFilter Treatment System M32* *Multiple units, in the same or a variety of sizes, may be used in parallel to accomplish daily design flows to 3,500 gpd. | 120 (per each prefabricate d basin) | Upflow Media Filtration |

DOH 337-024 Page 23 of 53

| | | | |
|---|--|--|----------------------|
| Lowridge Onsite Technologies, LLC | | | |
| PO Box 1179 | OSCAR-II Series | | Treatment Vessel to |
| Lake Stevens, WA 98258 | OSII-240 | 240 | Dosing Tank w/ |
| , | OSII-300 | 300 | headworks dosed into |
| Tel: 877-476-8823 | OSII-360 | 360 | OSCAR Coils on 6" |
| E-mail: info@lowridgetech.com | OSII-450 | 450 | ASTM C-33 sand |
| Web: www.lowridgetech.com | OSII-480 | 480 | Treatment Sequence |
| | OSII-600 | 600 | |
| | | | |
| | *Multiple OSCAR coil units, in the same or a | | |
| | combination of sizes, may be used in series | | |
| | and/or parallel to accomplish daily design flows | | |
| | up to 3,500 gpd. Contact the manufacturer for | | |
| | specific design details. | | |
| | | | |
| | OSCAR-III Series | | Treatment Vessel to |
| | OSIII – 240 | 240 | Dosing Tank w/ |
| | OSIII – 300 | 300 | headworks dosed into |
| | OSIII – 360 | 360 | OSCAR Coils on 12" |
| | OSIII – 450 | 450 | ASTM C-33 sand |
| | OSIII – 480 | 480 | Treatment Sequence |
| | | | · |
| | *Multiple OSCAR coil units, in the same or a | | |
| | combination of sizes, may be used in series | | |
| | and/or parallel to accomplish daily design flows | | |
| | up to 3,500 gpd. Contact the manufacturer for | | |
| | specific design details. | | |
| | | | |
| | OSCAR-in-a-Box Series | | |
| | OSB - 240 | 240 | |

DOH 337-024 Page 24 of 53

| Manufacturers of R | Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | | |
|-----------------------------------|---|--|---|--|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | | |
| | OSB - 300 | 300 | Treatment Vessel to | | |
| | OSB - 360 | 360 | Dosing Tank w/ | | |
| | OSB - 450 | 450 | headworks dosed into | | |
| | OSB - 480 | 480 | OSCAR Coils on 12" | | |
| | OSB - 600 | 600 | ASTM C-33 sand inside a PVC-lined containment vessel with underdraineffluent collection to dispersal component. | | |
| Lowridge Onsite Technologies, LLC | | | | | |
| (continued) | OSCAR-XO2 Series XO2-500 XO2-750 XO2-1125 XO2-2250 XO2-3000 XO2-3500 | 500 750 1125 2250 3000 3500 | Attached & Suspended Growth | | |

DOH 337-024 Page 25 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
|----------------------------------|--|-------------------------|---------------------|
| | XO2 In-a-box (XO2 B) | | |
| | XO2 B - 240 | 240 | Attached & Suspende |
| | XO2 B - 300 | 300 | Growth |
| | XO2 B - 360 | 360 | |
| | XO2 B - 450 | 450 | |
| | XO2 B - 480 | 480 | |
| | XO2 B - 600 | 600 | |
| | *Multiple OSCAR coil units, in the same or a combination of sizes, may be used in series and/or parallel to accomplish daily design flows up to 3,500 gpd. Contact the manufacturer for specific design details. | | |

DOH 337-024 Page 26 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
|--|--|-------------------------|-------------------------|
| Norweco, Inc. | Singulair Wastewater Treatment System (960 | | |
| 220 Republic Street | series) | | |
| Norwalk, OH 44857-1196 | Singulair 960-500 | 500 | |
| | Singulair 960-500 | 600 | |
| Tel: 419-668-4471 | Singulair 960-750 | 750 | Suspended Growth |
| Fax: 419-663-5440 | Singulair 960-750 | 800 | with Filtration Process |
| E-mail: customerservice@norweco.com | Singulair 960-1000 | 1000 | |
| Web: <u>www.norweco.com</u> | Singulair 960-1250 | 1250 | |
| | Singulair 960-1500 | 1500 | |
| | Singulair 960LP-500 | 500 | |
| | Singulair 960LP-500 | 600 | |
| | Singulair 960LP-1000 | 1000 | |
| | Singulair 960-OP-500 | 500 | |
| | Singulair 960-OP-500 | 600 | |
| | Singulair 960-OP-1000 | 1000 | |

DOH 337-024 Page 27 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
|----------------------------------|--|-------------------------|-----------------------|
| | Singulair Wastewater Treatment System (TNT | | |
| | series) | | |
| | Singulair TNT-500 | 500 | |
| | Singulair TNT-500 | 600 | |
| | Singulair TNT-750 | 750 | Suspended Growth |
| | Singulair TNT-750 | 800 | with Filtration Proce |
| | Singulair TNT-1000 | 1000 | |
| | Singulair TNT-1250 | 1250 | |
| | Singulair TNT-1500 | 1500 | |
| | Singulair TNT-OP-500 | 500 | |
| | Singulair TNT-OP-500 | 600 | |
| | Singulair TNT-OP-1000 | 1000 | |

DOH 337-024 Page 28 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | |
|---|--|-------------------------|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
| Norweco, Inc. | | | |
| (continued) | Singulair Wastewater Treatment System TNT series with the Norweco AT1500 UV Unit | | |
| | Singulair TNT-500 – 1 UV Unit | 500 | |
| | Singulair TNT-500 – 2 UV Units | 600 | Suspended Growth |
| | Singulair TNT-750 – 2 UV Units | 750 | with Filtration Process |
| | Singulair TNT-750 – 2 UV Units | 800 | & UV Disinfection |
| | Singulair TNT-1000 – 2 UV Units | 1000 | Treatment Sequence |
| | Singulair TNT-1250 – 3 UV Units | 1250 | |
| | Singulair TNT-1500 – 3 UV Units | 1500 | |
| | Singulair TNT-OP-500 – 1 UV Unit | 500 | |
| | Singulair TNT-OP-500 – 2 UV Units | 600 | |
| | Singulair TNT-OP-1000 – 2 UV Units | 1000 | |
| | Hydro-Kinetic 600 FEU with Norweco AT 1500 UV disinfection unit | 500 | Activated Sludge, Anaerobic, Anoxic, Extended Aeration, Gravity Settling, and Filtration with UV Disinfection Treatment Sequence |

DOH 337-024 Page 29 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | |
|---|--|---|---|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
| Orenco Systems Inc. 814 Airway Avenue | AdvanTex® Wastewater Treatment System | | |
| Sutherlin, Oregon 97479 Tel: 800-230-9580 Tel: 541-459-4449 Fax: 541-459-2884 E-mail: jsoulia@orenco.com Web: www.orenco.com | *AX20 *AX20 - 2 *AX20 - 3 *AX20 - 4 *AX100 *AX100 - 2 *System applications greater than 6 bedrooms and applications other than single family residential will require a design review by Orenco Systems, Inc. | 500 1000 1500 2000 2500 3500 | Attached Growth Multipass Packed Bed Filter |
| | AdvanTex® Wastewater Treatment System (2 or 3 compartment recirculating tank) AX20RT AX25RT | 500 625 | |

DOH 337-024 Page 30 of 53

| Manufacturers of Registered Category 1 Proprietary On-site Treatment Products | | | lucts | |
|---|---|---|---|--|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
| Orenco Systems Inc. (continued) | AdvanTex® AX Series with Orenco UV disinfection unit AX20 with Orenco UV unit *AX20 – 2 with Orenco UV units - 2 *AX20 – 3 with Orenco UV units - 3 *AX20 – 4 with Orenco UV units - 4 *AX100 with Orenco UV units - 5 *AX100 – 2 with Orenco UV units - 7 *System applications greater than 6 bedrooms and applications other than single family residential will require a design review by Orenco Systems, Inc. | 500 1000 1500 2000 2500 3500 | Attached Growth Multipass Packed Bed Filter & UV Disinfection Treatment Sequence | |
| | AdvanTex® AX Series with Orenco UV disinfection unit AX20RT — with Orenco AX25RT — with Orenco-2 | 500 625 | Attached Growth Multipass Packed Bed Filter & UV Disinfection Treatment Sequence | |

DOH 337-024 Page 31 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process | |
|--|---|-----------------------------------|---|--|
| | AdvanTex® AX-MAX Series (with discharge pump assembly) AX-MAX075-14 AX-MAX125-21 AX-MAX175-28 | 1,875 3,125 3,500 | Attached Growth Multipass Packed Bed Filter | |
| Orenco Systems Inc. (continued) | AdvanTex AX-MAX Series with Orenco UV disinfection units (without discharge pump assembly) AX-MAX075-14 with Orenco UV units - 4 AX-MAX125-21 with Orenco UV units - 7 AX-MAX175-28 with Orenco UV units - 7 | 1,875 3,125 3,500 | Attached Growth Multipass Packed Bed Filter & UV Disinfection Treatment Sequence | |
| SeptiTech A subsidiary of Bio-Microbics, Inc 69 Holland Street Lewiston, ME 04240 Tel: 207-333-6940 Fax: 207-333-6944 | SeptiTech Treatment System STAAR 0.5 STAAR 0.75 STAAR 1.0 STAAR 1.2 STAAR 1.5 | 440 660 880 1200 1500 | Trickling Filter | |

DOH 337-024 Page 32 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
|-----------------------------------|--|-------------------------|-------------------|
| E-mail: <u>info@septitech.com</u> | | | |
| Web: <u>www.septitech.com</u> | SeptiTech Treatment System with nitrogen | | |
| | reduction | | |
| | STAAR 0.5D | 440 | Trickling Filter |
| | STAAR 0.75D | 660 | |
| | STAAR 1.0D | 880 | |
| | STAAR 1.2D | 1200 | |
| | STAAR 1.5D | 1500 | |

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
|---|--|---|--------------------------------|
| Aqua Test Inc. PO Box 1116 Black Diamond, WA 98010 | NIBBLER Wastewater Treatment Process NIBBLER SBP & NIBBLER CBP | 200 (when O&G is ≤50 mg/L) 137.5 (when O&G is >50 mg/L) | Attached & Suspended Growth |
| Tel: 1-800-221-3159 Tel: 425-432-9360 Fax: 425-413-9431 E-mail: office@aquatestinc.com Web: www.aquatestinc.com | NIBBLER Jr. | 500 | Attached & Suspended Growth |

DOH 337-024 Page 33 of 53

| Manufacturers of Registered Category 2 Proprietary On-site Treatment Products | | | |
|---|---|---|-----------------------------|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (gpd) | Treatment Process |
| Bio-Microbics, Inc. 16002 West 110 th Street Lenexa, KS 66219 Tel: 800-753-3278 Tel: 913-422-0707 Fax: 913-422-0808 E-mail: onsite@biomicrobics.com Web: www.biomicrobics.com | FAST Wastewater Treatment System MicroFAST 0.5 MicroFAST 0.75 MicroFAST 0.9 MicroFAST 1.5 MicroFAST 3.0 MicroFAST 4.5 MicroFAST 9.0 These models are also used in Category 1. Models designed to treat high- strength sewage with the O&G influent level to the MicroFAST < 50 mg/L. | 500 750 900 1500 3000 4500 9000 | Attached & Suspended Growth |
| | Models may be used in non-single family residential designs when the design is reviewed by Bio-Microbics Inc. and documentation of the review is provided. | | |

DOH 337-024 Page 34 of 53

| Manufacturers | of Registered Category 3 Propr | ietary On-site <i>Treatment</i> Pro | ducts |
|---|--|--|---------------------|
| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (persons or uses/day) | Treatment Process |
| Clivus Multrum, Inc. 15 Union Street Lawrence, MA 01840 Tel: 800-425-4887 Fax: 978-557-9658 E-mail: brian@clivusmultrum.com Web: www.clivusmultrum.com | Clivus Multrum Composting Toilet M1 M2 M3 M10 M12 M15 M18 M22 M28 M32 M35 M35 M54ADA Outback | 10-uses/day 15 uses/day 40 uses/day 60 uses/day 80 uses/day 100 uses/day 120 uses/day 80 uses/day 120 uses/day 120 uses/day 120 uses/day 10 uses/day 10 uses/day 10 uses/day 10 uses/day 10 uses/day | Composting Toilet |
| Research Products / Blankenship 2639 Andjon Drive Dallas, TX 75220 Tel: 800-527-5551 Tel: 214-358-4238 Fax: 214- 350-7919 E-mail: sales@incinolet.com Web: www.incinolet.com | Incinolet Electric Incinerating Toilet CF TR WB | 4-person 8-person 4/8-person | Incinerating Toilet |

DOH 337-024 Page 35 of 53

| Manufacturer/Contact Information | Product Name/Model | Rated Capacity (persons or uses/day) | Treatment Process |
|----------------------------------|---------------------------|--|-------------------|
| Sun-Mar Corporation | Sun-Mar Composting Toilet | | Composting Toilet |
| 5370 South Service Road | Excel | 3-person residential | |
| Burlington, Ontario, Canada | Centrex 2000 A/F | 4-person residential | |
| L7L 5L1 | Centrex 2000 A/F AC/DC | 3-person residential | |
| | Centrex 3000 A/F | 5-person residential | |
| Tel: 800-461-2461 | Centrex 3000 A/F AC/DC | 4-person-residential | |
| Tel: 905-332-1314 | Compact | 1-person residential | |
| Fax: 905-332-1315 | Spacesaver | 1-person residential | |
| E-mail: joelocicero@sun-mar.com | Sun-Mar Mobile | 1-person residential | |
| Web: www.sun-mar.com | Excel NE | 2-person residential | |

DOH 337-024 Page 36 of 53

| | Manufacturers of Registered Proprietary On-site Distribution Products | | | | | | | | |
|--|---|----------------------------------|------------------------------|--|--|--|--|--|--|
| Manufacturer Contact Information | Product Name/Model | Emitter Flow Rate Nominal GPH | Type of Distribution Product | | | | | | |
| Geoflow, Inc. 506 Tamal Plaza Corte Madera, CA 94925 Tel: 800-828-3388 Tel: 415-927-6000 Fax: 415-927-0120 | WaterflowPRO G-WFCL-16-4-24 G-WFPC-16-2-12 G-WFPC-16-4-12 G-WFPC-16-2-24 G-WFPC-16-4-24 | 1.3 0.6 0.9 0.6 0.9 | Dripline | | | | | | |
| E-mail: krf@geoflow.com Web: www.geoflow.com | WaterflowECO G-WFPC-17-1.6-24-ECO G-WFPC-17-2-24-ECO G-WFPC-17-4-24-ECO | 0.4 0.6 1.0 | Dripline | | | | | | |

DOH 337-024 Page 37 of 53

| Manufacturers of Registered Proprietary On-site Distribution Products | | | | | | |
|---|--|-------------------------------|------------------------------|--|--|--|
| Manufacturer Contact Information | Product Name/Model | Emitter Flow Rate Nominal GPH | Type of Distribution Product | | | |
| Infiltrator Water Technologies, LLC 4 Business Park Road PO Box 768 Old Saybrook, CT 06475 Tel: 800-221-4436 Tel: 860-577-7100 Fax: 860-577-7001 E-mail: info@infiltratorsystems.net Web: www.infiltratorwater.com | Infiltrator Chamber Leach Field System Standard ARC 36 ARC 36HC ARC 36 LP ARC 24 14" High Capacity 11" Standard Bio 2 Bio 3 High Capacity Equalizer 36 Equalizer 24 Quick4 Standard Quick4 High Capacity Quick4 Equalizer 36 Quick4 Equalizer 24 Quick4 Plus Standard Quick4 Plus Standard | N/A | Gravelless Chamber | | | |

DOH 337-024 Page 38 of 53

| Manufacturers of Registered Proprietary On-site Distribution Products | | | | | | |
|---|--|----------------------------------|------------------------------|--|--|--|
| Manufacturer Contact Information | Product Name/Model | Emitter Flow Rate Nominal GPH | Type of Distribution Product | | | |
| Infiltrator Water Technologies, LLC Continued | Engineered Aggregate Systems – EZFlow Products 1003-H 1003-T 1203-H 1003-H-GEO 1003-T-GEO 1203-H-GEO | N/A | Gravel Substitute | | | |
| Netafim 5470 E. Home Avenue Fresno, CA 93727 Tel: 888-638-2346 Tel: 585-615-6440 E-mail: mai.thao@netafimusa.com Web: www.netafimusa.com | Bioline Dripperline* 0.4 GPH Dripper 0.6 GPH Dripper 0.9 GPH Dripper *"Techfilter" disk filter with root inhibitor implanted into replaceable disk cartridge is optional. | | Dripline | | | |

DOH 337-024 Page 39 of 53

| | Manufacturers of Registered Proprietary On-site Distribution Products | | | | | | | |
|--|---|-------------------------------|------------------------------|--|--|--|--|--|
| Manufacturer Contact Information | Product Name/Model | Emitter Flow Rate Nominal GPH | Type of Distribution Product | | | | | |
| Prinsco, Inc. 1717 16 th Street NE | Prinsco Pro4 Onsite Chambers | | Gravelless Chamber | | | | | |
| Willmar, MN 56201 | Pro4/36 | | Gravelless Chamber | | | | | |
| Tel: (320) 222-6800 Tel: (800) 992-1725 | | | | | | | | |
| E-mail: blake.johnston@prinsco.co | | | | | | | | |
| <u>m</u> | | | | | | | | |
| Web: <u>www.prinsco.com</u> | | | | | | | | |

DOH 337-024 Page 40 of 53

SECTION 3 – List of Registered On-site Treatment and Distribution Products

The following pages present the current list of registered treatment and distribution products by product type, under the categories and allowances provided in WAC 246-272A. The list includes lists of the following:

- Treatment products
 - o Categories 1, 2, & 3
 - Treatment levels met as verified by test results using the protocol required by WAC 246-272A
 - Both proprietary and public domain
- Proprietary distribution technologies
 - o Gravelless Distribution Products
 - Subsurface Dripline Products

To locate the contact information for a product, find the product in the alphabetical list of manufacturers in Section 2. Unless this list contains specific model numbers, all models listed in Section 2 can be assumed to meet the applicable requirements for listing in this section.

If a certain product is not listed, or if a listed manufacturer's specific model number is not included on the list, the product IS NOT APPROVED for use in Washington State and may not be permitted by the local health officer.

Disclaimer

Product registration and listing does not constitute departmental approval of marketing, advertising, or labeling practices employed by a manufacturer, nor does it constitute an endorsement of these products, nor a preference among the manufacturers.

DOH 337-024 Page 41 of 53

Registered On-site *Treatment* **Products**

Category 1

| Proprietary Product Name / Model | TLA | TLB | TLC | TLD | TLE | TLN |
|--|----------|----------|----------|----------|----------|----------|
| AdvanTex AX-MAX075-14, AX-MAX125-21, AX-MAX175-28 with Orenco UV Units | ✓ | ✓ | | | | √ |
| AdvanTex AX20, AX20-2, AX20-3, AX20-4, AX100, AX100-2 | | | ✓ | ✓ | | ✓ |
| AdvanTex AX20RT and AX25RT | | | ✓ | ✓ | | |
| AdvanTex AX20, AX20-2, AX20-3, AX20-4, AX100, AX100-2 with Orenco UV Units | ✓ | ✓ | ✓ | ✓ | | |
| AdvanTex AX20RT and AX25RT with Orenco UV Units | ✓ | ✓ | ✓ | ✓ | | |
| AdvanTex AX-MAX, AX-MAX075-14, AX-MAX125-21, AX-MAX175-28 | | | ✓ | ✓ | | ✓ |
| Aqua Aire Series AA500, AA600, AA750, AA800, AA1000, AA1200, AA1500 | | | | ✓ | | |
| Aqua Safe AS600 + 4RN | | | | ✓ | ✓ | |
| Aqua Safe AS600 + 4RN w/ Disinfector UV and Salcor 3G UV | | ✓ | | | | |
| Aqua Safe Series AS500, AS600, AS750, AS1000, AS1500, AS500L, AS600L, AS800L, and AS1100L | | | | ✓ | ✓ | |
| BioBarrier MBR 0.5, 1.0, and 1.5 | ✓ | √ | ✓ | ✓ | | |
| BioBarrier MBR 0.5-N, 1.0-N, and 1.5-N | ✓ | ✓ | ✓ | ✓ | | ✓ |
| Busse MBR GT400, GT500, GT800, GT1000, & GT1200 | ✓ | ✓ | ✓ | ✓ | | |
| Clearstream 500 G Series Aerobic Treatment Units with CS 120 UV disinfection unit 500G/GC, 500GS/GSC, 500GST, 500GT, 500GC2, 500GC2P, 500GC3-500, 500GC3-750 | √ | | | | | |
| Clearstream Aerobic Treatment Units 500D/DC, 500DS/DSC, 500DST, 500DC2, 500DC2P, 500DC3-500, 500DC3-750, 600D/DC, 600DT, 600DC2, 600DC3, 1000DD, 1000DCD, 1000DTD | | ✓ | | | | ✓ |
| Clearstream Aerobic Treatment Units 500G/GC, 500GS/GSC, 500GST. 500GT, 500GC2, 500GC2P, 500GC3-500, 500GC3-750, 600G/GC, 600GT, 600GC2, 600GC3, 1000GD, 1000GCD, 1000GTD | | | √ | | | |

DOH 337-024 Page 42 of 53

| Proprietary Product Name / Model | TLA | TLB | TLC | TLD | TLE | TLN |
|--|----------|----------|----------|----------|-----|----------|
| Clearstream Aerobic Treatment Units 500DA/DAC, 500DAS/DASC, 500DAST, 500DAT, 500DAC2, 500DAC3- 500, 500DAC3-750, 500DAU, 600DA/DAC, 600DAT, 600DAC2, 600DAC3, 600DAU, 800DA/DAC, 800DAT, 800DAC2 | | ✓ | | | | |
| ECOPOD E50 and E60 with Salcor 3G UV | | ✓ | | | | |
| ECOPOD E50, E60 | | | | ✓ | ✓ | |
| ECOPOD E50-N, E60-N, E75-N | | | | | | |
| ECOPOD E50NCA, E60NCA, E75NCA, E100NCA, E150NCA, E200-NFF, E250-NFF, E300-NFF, E50-N-IM1060, E60-N-IM1060, E75-N-IM1060 | | | ✓ | ✓ | | ✓ |
| ECOPOD E50NCA, E60NCA, E75NCA, E100NCA, E150NCA, E200-NFF, E250-NFF, E300-NFF, E50-N-IM1060, E60-N-IM1060, E75-N-IM1060 with Salcor 3G UV | ✓ | ✓ | | | | ✓ |
| ECOPOD E50NCA, E60NCA, E75NCA, E100NCA, E150NCA, E200-NFF, E250-NFF, E300-NFF, E50-N-IM1060, E60-N-IM1060, E75-N-IM1060 with Jet Illumi-Jet UV | ✓ | ✓ | | | | ✓ |
| ECOPOD E50NCA, E60NCA, E75NCA, E100NCA, E150NCA, E200-NFF, E250-NFF, E300-NFF, E50-N-IM1060, E60-N-IM1060, E75-N-IM1060 with Norweco AT 1500 UV | ✓ | ✓ | | | | ✓ |
| Eljen GSF/A42 | | | ✓ | | | |
| Enviro-Flo E-500, E-550, E-600, E-750, & E-1000 | | | | ✓ | ✓ | |
| Enviro-Guard ENV-0.75 with Salcor 3G UV | ✓ | ✓ | | | | |
| Fuji Clean CEN5, CEN7, CEN10 with Salcor 3G UV | ✓ | ✓ | | | | |
| Fusion ZF450, ZF600, ZF800 | | | | ✓ | ✓ | |
| Glendon BioFilter M31 | ✓ | ✓ | ✓ | | | |
| Glendon BioFilter M32 | ✓ | ✓ | ✓ | | | |
| Hydro-Kinetic 600 FEU with Norweco AT 1500 UV | ✓ | ✓ | | | | ✓ |
| MicroFAST 0.5, 0.625, 0.75, 0.9, 1.5, 3.0, 4.5, 9.0 | | | | ✓ | ✓ | ✓ |
| MicroFAST 0.5, 0.625, 0.75, 0.9, 1.5, 3.0, 4.5, 9.0 with Salcor 3G UV | ✓ | ✓ | | | | ✓ |
| MicroFAST 0.5, 0.625, 0.75, 0.9, 1.5, 3.0 with Norweco AT 1500 UV | ✓ | ✓ | | | | ✓ |

DOH 337-024 Page 43 of 53

| <u>Proprietary</u> Product Name / Model | TLA | TLB | TLC | TLD | TLE | TLN |
|--|----------|-------------|----------|----------|----------|----------|
| Multi-Flo FTB-0.5, FTB-0.6, FTB-0.75, FTB-1.0, FTB-1.5 | | | | ✓ | ✓ | |
| Nayadic M-6A-F/M-6, M-6A-C/M-6AC-F, M-8A-F/M-8A, M-1050-F/M-1050A, M-1200-F/M-1200A, M-2000-F/M-2000A | | | | ✓ | ✓ | |
| NuWater B-500 with Salcor 3G UV | | ✓ | | | | |
| NuWater BNR-500, BNR-600, BNR-750, BNR-850, BNR-1000, BNR-1500 | | ✓ | ✓ | ✓ | | |
| NuWater BNR-500, BNR-600, BNR-750, BNR-850, BNR-1000, BNR-1500with Salcor 3G UV | ✓ | > | | | | |
| OSCAR-II Series: OSII-240, OSII-300, OSII-360, OSII-450, OSII-480, OSII-600 | | | ✓ | | | |
| OSCAR-III Series OSIII – 240, OSIII – 300, OSIII – 360, OSIII – 450, OSIII - 480 | | ✓ | ✓ | | | |
| OSCAR-in-a-Box TM | | ✓ | ✓ | | | |
| OSCAR-XO2 | ✓ ✓ | ✓ | √ | | | |
| XO2-in-a-box (XO2 B) Puraflo Peat Fiber Biofilter P150N 3A, P150N 4A, P150N 5A, and P150N 6A | V | ✓ | ✓ | | ✓ | |
| Puraflo Peat Fiber Biofilter P150N 3B, P150N 4B, P150N 5B, P150N 6B, P150N 7B, P150N 8B, P150N 9B, and P150N 10B | | | √ | ✓ | ✓ | |
| RetroFAST 0.375 | | | | | ✓ | ✓ |
| SeptiTech STAAR 0.5,0.75,1.0,1.2,1.5 | | | | ✓ | ✓ | |
| SeptiTech STAAR: 0.5D,0.75D,1.0D,1.2D,1.5D | | | | | ✓ | ✓ |
| Singulair 960-500, 960-750, 960-1000, 960-1250, 960- 1500, 960LP-500, 960LP-1000, 960-OP-500, 960-OP-1000 | | | | ✓ | √ | |
| Singulair TNT-500, TNT-750, TNT-1000, TNT-1250, TNT- 1500, TNT-OP-500, TNT-OP-1000 | | | | √ | √ | ✓ |
| Singulair TNT-500, TNT-750, TNT-1000, TNT-1250, TNT- 1500, TNT-OP-500, TNT-OP-1000 with Norweco AT1500 UV Unit | ✓ | √ | | | | ✓ |
| SludgeHammer S-400 series | | | | ✓ | | |
| Whitewater DF50 and DF60 with Salcor 3G UV | ✓ | ✓ | | | | |

DOH 337-024 Page 44 of 53

| <u>Proprietary</u> Product Name / Model | TLA | TLB | тьс | TLD | TLE | TLN |
|--|----------|----------|-----|----------|-----|-----|
| Whitewater DF50 and DF60 with Jet Illumi-Jet UV | ✓ | √ | | | | |
| Whitewater DF50 and DF60 with Norweco AT 1500 UV | ✓ | ✓ | | | | |
| Whitewater DF75, DF100, DF100A, DF150 | | | | ✓ | ✓ | |

DOH 337-024 Page 45 of 53

Category 1

| Public Domain Technology Name* | TLA | TLB | ТLС | TLD | TLE | TLN |
|---|-----|----------|----------|-----|-----|-------------------------|
| Intermittent Sand Filter System | | ✓ | ✓ | ✓ | | |
| Mound System | | ✓ | ✓ | | | |
| Recirculating Gravel Filter System | | | √ | ✓ | | 50% of Total N |
| Recirculating Gravel Filter System w/VWDB | | | ✓ | ✓ | | ✓ |
| Sand Lined Trenches/ Bed System | | ✓ | ✓ | | | |
| Stratified Sand Filter System | ✓ | ✓ | ✓ | ✓ | | |

^{*} Listed treatment technologies meet levels of treatment performance when constructed and used according to their respective departmental recommended standards and guidance documents.

Category 2

| Proprietary Product Name / Model | TLE | High Strength Commercial | High Strength Residential | Treatment Capacity (pounds per day for CBOD₅) |
|----------------------------------|-----|-----------------------------|---------------------------------|---|
| NIBBLER SBP & NIBBLER CBP | ✓ | ✓ | ✓ | 0.81 |
| NIBBLER Jr. | ✓ | | ✓ | 1.0 |
| MicroFAST 0.5 | ✓ | | ✓ | 1.0 |
| MicroFAST 0.75 | ✓ | | ✓ | 1.5 |
| MicroFAST 0.9 | ✓ | | ✓ | 2.0 |
| MicroFAST 1.5 | ✓ | | ✓ | 3.2 |
| MicroFAST 3.0 | ✓ | | ✓ | 6.4 |
| MicroFAST 4.5 | ✓ | | ✓ | 9.5 |
| MicroFAST 9.0 | ✓ | | ✓ | 17.0 |

DOH 337-024 Page 46 of 53

Registered On-site *Treatment* Products (cont'd)

Category 3

| Incinerating Toilets | | | | | |
|---|------------|---------|--|--|--|
| Product Name / Model Rated Capacity (persons) Voltage (V) | | | | | |
| Incinolet Electric Incinerating Toilet | | | | | |
| Incinolet CF | 4-person | 120 | | | |
| Incinolet TR | 8-person | 240 | | | |
| Incinolet WB | 4/8-person | 120/240 | | | |

Category 3

| Composting Toilets | | | | | | | |
|----------------------------------|---|-------------|--|--|--|--|--|
| Product Name / Model | Rated Capacity (persons or uses/day) | Voltage (V) | | | | | |
| Clivus Multrum Composting Toilet | | | | | | | |
| M1 | 10-uses/day | 115 or 12 | | | | | |
| M2 | 15-uses/day | 115 or 12 | | | | | |
| M3 | 40-uses/day | 115 or 12 | | | | | |
| M10 | 60-uses/day | 115 or 12 | | | | | |
| M12 | 80-uses/day | 115 or 12 | | | | | |
| M15 | 100-uses/day | 115 or 12 | | | | | |
| M18 | 120-uses/day | 115 or 12 | | | | | |
| M22 | 80-uses/day | 115 or 12 | | | | | |
| M28 | 120-uses/day | 115 or 12 | | | | | |
| M32 | 110-uses/day | 115 or 12 | | | | | |
| M35 | 180-uses/day | 115 or 12 | | | | | |
| M54ADA | 60-uses/day | 12 or 115 | | | | | |
| Outback | 0-20 uses/day | 110 or 12 | | | | | |
| Sun-Mar Composting Toilet | Sun-Mar Composting Toilet | | | | | | |
| Excel | 3-person residential | 115 | | | | | |

DOH 337-024 Page 47 of 53

| Composting Toilets | | | | | |
|------------------------|--------------------------------------|------------------|--|--|--|
| Product Name / Model | Rated Capacity (persons or uses/day) | Voltage (V) | | | |
| Centrex 2000 A/F | 4-person residential | 115 | | | |
| Centrex 2000 A/F AC/DC | 3-person residential | 115 & 12 | | | |
| Centrex 3000 A/F | 5-person residential | 115 | | | |
| Centrex 3000 A/F AC/DC | 4-person-residential | 115 & 12 | | | |
| Compact | 1-person residential | 115 | | | |
| Spacesaver | 1-person residential | 115 | | | |
| Sun-Mar Mobile | 1-person residential | 12 & 115 | | | |
| Excel NE | 2-person residential | Non- electric | | | |

DOH 337-024 Page 48 of 53

Registered On-site *Distribution* Products

| Gravelless Chamber Products | | | | | | |
|--|---|------------------------------------|--|--|---|--|
| Product / Model | Unit Size Outside Dimensions W / L / H (inches) | Void Space per unit (cu. ft) | Void Space per linear foot (cu. ft) | Infiltrative Surface per unit (sq. ft.) | Infiltrative Surface per linear foot (sq. ft.) | |
| Infiltrator Chamber Lea | ach Field System | | | | | |
| Standard | 34" x 75" x 12" | 10.3 | 1.65 | 17.69 | 2.83 | |
| ARC 36 | 33.75" x 60" x 13" | 8.5 | 1.7 | 14.38 | 2.88 | |
| ARC 36HC | 33.75" x 60" x 16" | 10.5 | 2.09 | 14.38 | 2.88 | |
| ARC 36 LP | 33.8" x 60" x 8" | 5.80 | 1.16 | 14.08 | 2.82 | |
| ARC 24 | 22.5" x 60" x 12" | 5.02 | 1.0 | 9.38 | 1.88 | |
| 14" High Capacity | 34" x 76" x 14" | 14.0 | 2.25 | 17.9 | 2.8 | |
| 11" Standard | 34" 76" x 11" | 8.5 | 1.36 | 17.9 | 2.8 | |
| Bio 2 | 15.38" x 86.9" x 12.38" | 5.0 | 0.7 | 9.0 | 1.3 | |
| Bio 3 | 22" x 86.9" x 12.38" | 8.6 | 1.2 | 13.2 | 1.8 | |
| High Capacity | 34" x 75" x 16" | 16.3 | 2.61 | 17.69 | 2.83 | |
| Equalizer 36 | 22" x 100" x 13" | 8.42 | 1.00 | 15.24 | 1.83 | |
| Equalizer 24 | 15" x 100" x 11" | 4.45 | 0.54 | 10.41 | 1.25 | |
| Quick4 Standard | 34" x 48" x 12" | 5.82 | 1.46 | 11.32 | 2.83 | |
| Quick4 Plus Standard | 34" x 48" x 12" | 6.20 | 1.55 | 11.32 | 2.83 | |
| Quick4 Plus Standard Low Profile (LP) | 34" x 48" x 8" | 4.28 | 1.07 | 11.32 | 2.83 | |
| Quick4 Plus All-In- One Endcap | 18" x 13" x 8" | 0.68 | NA | 1.6 | NA | |
| Quick4 Plus All-In- One Endcap | 18" x 10" x 8" | 0.60 | NA | 1.3 | NA | |
| Quick4 Plus Endcap | 18" x 4" x 8" | 0.14 | NA | 0.6 | NA | |
| Quick4 Standard MultiPort End Cap | 34" x 16" x 12" | 1.22 (average per unit) | NA | 2.43 (average per unit) | NA | |
| Quick4 HiCap | 34" x 48" x 16" | 8.30 | 2.08 | 11.32 | 2.83 | |
| Quick4 HiCap MultiPort End Cap | 34" x 19" x 16" | 1.93 (average per unit) | NA | 3.00 (average per unit) | NA | |
| Quick4 EQ36 | 22" x 48" x 12" | 4.30 | 1.08 | 7.32 | 1.83 | |
| Quick4 EQ36 MultiPort End Cap | 22" x 16" x 12" | 0.74 (average per unit) | NA | 1.65 (average per unit) | NA | |
| Quick4 EQ24 | 16" x 48" x 11" | 2.78 | 0.70 | 5.32 | 1.33 | |

DOH 337-024 Page 49 of 53

| Gravelless Chamber Products | | | | | | | |
|----------------------------------|---|------------------------------------|--|--|---|--|--|
| Product / Model | Unit Size Outside Dimensions W / L / H (inches) | Void Space per unit (cu. ft) | Void Space per linear foot (cu. ft) | Infiltrative Surface per unit (sq. ft.) | Infiltrative Surface per linear foot (sq. ft.) | | |
| Quick4 EQ24 MultiPort End Cap | 16" x 14" x 12" | 0.52 (average per unit) | NA | 1.20 (average per unit) | NA | | |
| Prinsco Gravelless Char | mber | | | | | | |
| Pro4/36 | 34" x 48" x 12" | 6.88 | 1.72 | 11.32 | 2.83 | | |
| Pro4/36 Endcap | 29" x 16" x 12" | 0.93 | NA | 1.69 | NA | | |

| Geocomposite Drainfield | | | | | | | |
|---|------------------------------------|---|---|---|--|---|--|
| Product / Model | Unit Size W / L / H (inches) | Void Space per foot ³ of media (cu. ft) | Void Space per arrangemen t of units (cu. ft) | Void Space per linear foot of trench (cu. ft) | Infiltrative Surface per arrangement units (sq. ft.) | Infiltrative Surface per linear foot (sq. ft.) | |
| Eljen GSF Geotextile Sand Filter System | | | | | | | |
| GSF/A42 module | 24" x 48" x 7" | 0.52 | 4.2 | 1.1 | 8 | 2 | |

DOH 337-024 Page 50 of 53

Registered On-site *Distribution* Products (cont'd)

| Gravel Substitute Products | | | | | | |
|----------------------------|--|--|--|---|---|---|
| Product / Model | Unit Size W / L / H (inches) | Void Space per foot ³ of media (cu. ft) | Void Space per arrangem ent of units (cu. ft) | Void Space per linear foot of trench (cu. ft) | Infiltrativ e Surface per arrange ment of units (sq. ft.) | Infiltrative Surface per linear foot (sq. ft.) |
| Infiltrator Engine | eered Aggregate Systems | | | | | |
| 1003-Н | 30" x 120" x 10" Horizontal arrangement of three 10" diameter "tubes" in a 30" wide trench. | 0.4 | 7.2 | 0.72 | 25 | 2.5 |
| 1003-T | 24" x 120" x 10" Triangular arrangement of three 10" diameter "tubes" in 24" wide trench. | 0.4 | 7.2 | 0.72 | 20 | 2.0 |
| 1203-Н | 36" x 120" x 12" Horizontal arrangement of three 12" diameter "tubes" in a 36" wide trench. | 0.4 | 10.1 | 1.01 | 30 | 3.0 |
| 1003-H-GEO | 30" x 120" x 10" Horizontal arrangement of three 10" diameter "tubes" with geotextile in a 36" wide trench. | 0.4 | 7.2 | 0.72 | 25 | 2.5 |
| 1003-T-GEO | 24" x 120" x 10" Triangular arrangement of three 24" diameter "tubes" in a 24" wide trench | 0.4 | 7.2 | 0.72 | 20 | 2.0 |

DOH 337-024 Page 51 of 53

| | Gravel Substitute Products | | | | | | |
|--------------------|--|--|--|---|---|---|--|
| Product / Model | Unit Size W / L / H (inches) | Void Space per foot ³ of media (cu. ft) | Void Space per arrangem ent of units (cu. ft) | Void Space per linear foot of trench (cu. ft) | Infiltrativ e Surface per arrange ment of units (sq. ft.) | Infiltrative Surface per linear foot (sq. ft.) | |
| 1203-H-GEO | 36" x 120" x 12" Horizontal arrangement of three 12" diameter "tubes" with geotextile in a 36" wide trench. | 0.4 | 10.1 | 1.01 | 30 | 3.0 | |
| FTSG103H-1 | 30" x 120" x 10" Horizontal arrangement of three 12" diameter "tubes" with geotextile in a 36" wide trench. | 0.4 | 7.2 | 0.72 | 25 | 2.5 | |
| FTSG103T-1 | 24" x 120" x 10" Triangular arrangement of three 10" diameter "tubes" with geotextile in a 24" wide trench. | 0.4 | 7.2 | 0.72 | 20 | 2.5 | |
| FTSG123H-1 | 36" x 120" x 12" Horizontal arrangement of three 12" diameter "tubes" in a 36" wide trench. | 0.4 | 10.1 | 1.01 | 30 | 3.0 | |

DOH 337-024 Page 52 of 53

Registered On-site *Distribution* Products (cont'd)

| Subsurface Dripline Products | | | | | | | |
|-------------------------------------|-----------------------|------------------------------------|--------------------------------|--|--|--|--|
| Product Name / Model | Pipe I.D. (inches) | Emitter Discharge Rate (GPH) | Emitter Spacing (inches) | Emitter Type | | | |
| **Geoflow WaterFlow PC 0.6 GPH | 0.55 | 0.6 | 24, 18, 12, & 6 | Pressure compensating | | | |
| Geoflow WaterFlow PC 0.9 GPH | 0.55 | 0.9 | 24, 18, 12, & 6 | Pressure compensating | | | |
| Geoflow Waterflow Classic | 0.55 | 1.3 at 20 PSI | 24.18, 12, & 9 | Non-compensating (requires pressure regulator) | | | |
| Netafim Bioline Dripperline 0.4 GPH | 0.57 | 0.42 | 24, 18, 12 | Pressure compensating | | | |
| Netafim Bioline Dripperline 0.6 GPH | 0.57 | 0.62 | 24, 18, 12 | Pressure compensating | | | |
| Netafim Bioline Dripperline 0.9 GPH | 0.57 | 0.92 | 24, 18, 12 | Pressure compensating | | | |

^{**} Geoflow WaterFlow PC 0.55GPH now 0.6 GPH Difference per emitter is 0.1 gph or 0.002 gpm or 0.017 gallons over 10 mins. Difference for a 500 ft coil at 24inch spacing is 0.42 gpm.

DOH 337-024 Page 53 of 53